

Addendum No. 2

Date: August 10, 2011

To: All Bidders and Plan Holders

From: Jeffrey M. Saylor, AIA, LEED AP
Vice President
Abonmarche Consultants, Inc.

Owner: Boys & Girls Club of Benton Harbor
1200 E. Main Street
Benton Harbor, MI 49022

Project: Teen Center Property – Demolition of Existing Structures

Project No. 10-0715 D

SCOPE OF WORK:

The following items are changes to and/or clarifications of the drawings and specifications, and shall be included in the Bid Proposal. All of these items will be part of the Contract Documents. The Bidder will acknowledge receipt of this Addendum in the appropriate space provided on the Bid Form. Failure to do so may result in disqualification of the Bid.

SPECIFICATIONS:

1. Section 02120 Demolition, 3.01, B1. Add third paragraph as follows:

“Note: Contractor must remove existing watermain – cut off and cap line just after curb stop – prior to building demolition.”

END ADDENDUM NO. 2